

## Smoke + Carbon Monoxide Alarm

AC POWERED SMOKE + CARBON MONOXIDE ALARM WITH 10-YEAR SEALED BATTERY BACKUP AND VOICE & LOCATION

### SMC0110V-AC

CAT. 1046791

**10 YEAR**  
**10-YEAR FACTORY SEALED BATTERY BACK UP**

**VOICE WARNING WITH LOCATION**

**LATCHING ALARM INDICATOR**



**10-YEAR SEALED BATTERY BACKUP**

10-years of continuous protection with no battery change required and protection during power outages.

**VOICE WARNING WITH LOCATION**

Voice tells what the danger is and its location.

**LATCHING ALARM INDICATOR**

Visually identifies unit that initiated alarm or low battery.

**ADVANCED SMOKE & CO PROTECTION**

Advanced sensing technology for early warning and less cooking nuisance alarms.

**TEST/SILENCE BUTTON**

Temporarily silence or test the alarm with one-touch, easy access button.

**DUST COVER**

Keeps alarm clean during construction.



### ARCHITECTURAL AND ENGINEERING SPECS

The smoke alarm shall be a BRK Model SMC0110V-AC and shall provide at a minimum the following features and functions:

1. A photoelectric smoke sensing chamber and an electrochemical CO sensor both with a 10 year service life.
2. Powered by 120V AC, 60Hz and have a 10-Year Sealed Lithium Battery backup and a solid state piezo horn rated at 85dB at 10 ft. and shall be capable of self restoring.
3. A Voice Warning of Smoke or Carbon Monoxide detected in addition to speaking several pre-programmed locations, e.g. "Warning, Evacuate, Smoke in Basement"
4. The unit shall have an "End of Life" signal (5 chirps). This signal should be capable of temporarily being silenced for up to 2 days. After about 2 days, the signal will resume. After about 2 weeks the signal cannot be silenced.
5. A visual power-on indicator to confirm unit is receiving AC power or has switched to battery backup mode. Separate LED 's to indicate a smoke or CO alarm.
6. The CO sensor is adjusted not to detect CO levels below 30 PPM and will not alarm when exposed to constant levels of 30 PPM for 30 days. It will alarm at the following levels: 400 PPM CO between 4 and 15 minutes, 150 PPM CO between 10 and 50 minutes and 70 PPM CO between 60 and 240 minutes.
7. Two Latching features: Alarm Latch to easily identify initiating alarm after alarm condition has subsided. End of Life Battery Latch: to visually identify which unit is in low battery condition. Silence Features: Alarm Silence to temporarily silence nuisance alarms.
8. Sealed battery backup compartment.
9. The unit shall be capable of operating between 40°F (4°C) and 100°F (38°C) and relative humidity between 10% and 95%.
10. The unit shall have a plug in connector and be capable of interconnection of up to 18 alarms, 12 of which can be smoke alarms.
11. The unit meets the applicable requirements of UL217 and UL2034, CSFM, NFPA 72 and the ICC.

### INSTALLATION OF ALARM

Installation of this smoke alarm should be performed by a qualified electrician in accordance with the National Electrical Code NFPA 70, NFPA 72 and any other applicable codes or standards in a manner acceptable to the authority having jurisdiction. The interconnect wire should be a maximum of 1000 ft. and rated at least 300V.

### TECHNICAL SPECS

Alarm Dimensions:	5.02" Dia. x 1.9" H
Weight:	0.45 lb
Operating Voltage:	120V AC 60Hz
Battery:	3V Lithium
Temperature Range:	40°F (4.4°C) to 100°F (37.8°C)
Humidity Range:	10% to 95% relative humidity (RH)
Audio Alarm:	85dB at 10 feet
Test/Silence:	Electronically simulates smoke condition, causing the unit to alarm. Press and hold test/silence button.
Alarm Reset:	Automatic when smoke clears
Interconnections:	Up to 18 units of First Alert or BRK Smoke, CO and Heat Alarms. Maximum of 12 smoke alarms. See user's manual.
Smoke Sensor:	Photoelectric
Indicator Lights/Sounds:	
AC Power:	Constant Green
DC Power:	Flashes Green every minute
Smoke Alarm:	3 Beeps, Flashes Red
CO Alarm:	4 Beeps, Flashes Red
Latching Alarm:	Flashes Red 2 sec. on / 2 sec. off after alarm
Low Battery / End of Life:	5 "Chirps" every Minute – Replace Alarm
Malfunction:	3 "Chirps" every Minute – Replace Alarm
Listing:	Certified to UL217 & UL2034